



**Executive Engineer, W/S & Sanitation Division,
Shaheed Bhagat Singh Nagar**

Tele/fax: 01823-221184

e-mail: eevss.divsbhagatsnagarpb@yahoo.com

No.

4647


Dated:- 17/04/2023

Certificate of Sanitary Condition

Reference:-

Sub division Engineer, water supply & Sanitation sub division no.1
Nawanshahr Letter No. 749 Date 13.04.2023

As per Request Letter from school authority for issuing Certificate of Sanitary of water condition of Raja Sahib Public Sen.Sec.School, village Jhingran, Distt SBS Nagar. This is to certify that Er.Jasvir Singh JE, DWSS Sub Div No.1 Nawanshahr inspected the premises of Raja Sahib Public Sen.Sec.School, village Jhingran, Distt SBS Nagar . On inspection, there are sufficient Number of school Toilets (Boys/Girls Students & Ladies/Gents Staff). Toilets are well ventilated, neat and clean. Sanitary conditions are good, Bathrooms are found clean and good for use of Student and Staff. This certificate is valid for 1 year.


Executive Engineer
W/S & Sanitation Division
SBS Nagar

17/04/2023

DISTRICT WATER TESTING LABORATORY, SBS NAGAR

District Water Testing Laboratory, Department of Water Supply and Sanitation, Village Saloh, SBS Nagar, Punjab
dwtsbs@gmail.com

To,

Raja Sahib Public Sen.Sec. School Jhingran
Raja Sahib Public Sen.Sec. School Jhingran, SBS Nagar

No.: DWTLSBS/2223/00161 Dated : 21/03/2023

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. Letter No. RSPS-124 Dated: 20/02/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 22/02/2023. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, SBS Nagar

D/A : Test Report



Authorized Signatory
For, District Water Testing Laboratory, SBS
Nagar

DISTRICT WATER TESTING LABORATORY, SBS NAGAR

District Water Testing Laboratory, Department of Water Supply and Sanitation, Village Saloh, SBS Nagar, Punjab
dwtlsbs@gmail.com



TEST REPORT

Name & Address of Customer : Raja Sahib Public Sen.Sec. School Jhingran Raja Sahib Public Sen.Sec. School Jhingran, SBS Nagar		Customer Reference No.	No : Letter No. RSPS-124 Dated : 20/02/2023			
		Sample Submitted by	Sarbjit Singh			
		Date of Sample Receipt	22/02/2023			
		Analysis Starting Date	06/03/2023			
		Analysis completion Date	07/03/2023			
Discipline : Chemical Testing		Group: Water				
ULR No.:	TC98812300000021F	Sample Type :	Water			
Test Report No.:	DWTL SBS/2223/00161	Date of Issue :	21/03/2023			
Registration no.:	DWTL SBS/REG2223/00792	Condition of Sample :	Unsealed			
Source :	Not Mentioned	Quantity/Type of Bottle:	1000 ml / Plastic Bottles			
Scheme :	Not Mentioned	Location/Depth :	Raja Sahib Public Sen.Sec. School Jhingran / NA			
Village :	Jhingran	Habitation :	Jhingran			
Block:	Aur	District :	SBS Nagar			
Latitude :	Not Mentioned	Longitude:	Not Mentioned			
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.40	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 1984) (RA 2017)
5	TDS	150	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	0.7	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	56	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	60	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
9	Calcium	14.42	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	5.83	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method

DISTRICT WATER TESTING LABORATORY, SBS NAGAR

District Water Testing Laboratory, Department of Water Supply and Sanitation, Village Saloh, SBS Nagar, Punjab
dwtsbs@gmail.com



11	Chloride	15	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method
----	----------	----	-----	------	------	---

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used be as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.

Mr. Manik Kataria
Sr. Chemist
Authorized Signatory
For, District Water Testing Laboratory, SBS Nagar

----- End of the Test Report -----

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 4647

Dated.17-04-2023

It is certified that an inspection team headed by Jasvir Singh (Junior Engineer)
 (Name of officers with designation) from Sub division Engineer, water supply & sanitation sub division
no. 1 Nawanshahr Letter No. 749

(Name of department /Office) Inspected the Raja Sahib public Sen. Sec. School, Jhingran , The Banga
Distt ,SBS Nagar, Punjab (144507)

(Name and address of the school) on 15-04-2023 (date of inspection) and found that

Raja Sahib public Sen. Sec. School, Jhingran (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is main maintaining the Hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central State/ UT Govt.

The above is valid for a period of 01-04-2023 to 31-03-2024

Signature with seal.....

Name: Parsandeep Singh

Designation: Executive Engineer W/S & Sanitation

Division

Name & Address of the Office/ Department.

To

Raja Sahib public Sen. Sec. School, Jhingran

Teh-Banga, Distt: SBS Nagar , Punjab (144507)

(Name & address of the institution)



The filled up a certificate should be either in Hindi or English. If it is issued in Vernacular language, Translated notarized version in English be uploaded along with the original Vernacular Certificate as a single PDF.

Translation of the Document Produced

ATTESTED

Notary Public Nawanshahr (Pb.) India

16 MAY 2023